


# **Power OFF-delay TIMER**

## Order Code



### **Technical criteria**

Rated supply voltage	100 to 125 VDC		
Power On time	2 s min		
Operating Temperature	–10 to 55 °C		
Reset Input type	—		
Reset input time			
Output	Contact Output: Instantaneous operation/Time-limit reset (DPDT) 5A at 250 VAC/30 VDC, 0.15A at 125 VDC, resistive load ( $\cos \phi = 1$ ) Minimum applied load: 10mA at 5 VDC (failure level: P, reference value) Contact materials: Ag-alloy		
Accuracy of operating Time	$\pm 0.2\%$ Full Scale max. ( $\pm 0.2\%$ FS $\pm 10$ ms max. in ranges of 0.6 and 1.2 s)		
Setting error	±5% Full Scale ±50 ms max.		
Operation start voltage	30% max. of rated voltage		
Influence of voltage	±0.2% Full Scale max. (±0.2% FS ±10 ms max. in ranges of 0.6 and 1.2 s)		
Influence of temperature	±1% Full Scale max. (±1% FS ±10 ms max. in ranges of 0.6 and 1.2 s)		
Operating mode	Power OFF-delay		
Safety Standards	UL 508, CSA C22.2 No.14 CCC CE Marking under EN 61812-1, IEC 60664-1 Marine Approvals (NK, Lloyds) For the most recent information on models that have been certified for safety standards, refer to your OMRON website.		

#### Nomenclature

Output indicator



Time setting knob (for setting power OFF-delay time)

Time range selector (select one from 0.6, 1.2, 6, and 12 at full scale)


Time unit display M-series: min

#### **Time range**

Time unit		M-series
Scale number (max.)		min (minute)
0.6	Set time range	0.05 to 0.6
1.2		0.12 to 1.2
6	Set time range	0.6 to 6
12		1.2 to 12
Min. power ON time		2 s min.
Time-up operation repeat period		3 s min.
Forced-reset repeat period		3 s min.

Note: 1. If the above minimum power ON time is not secured, the H3CR may not operate. Be sure to secure the above minimum power ON time.2. Do not use the Timer with a repeat period of less than 3 s. Doing so may result in abnormal heating or burning.

### **Timing Chart**



t: Set time

Rt: Minimum power ON time (2 s min.)

If the power ON time is less than this value, the Timer may not operate (i.e., output may not turn ON).

Note: If the power is turned ON until the set time is up, the timer will be retriggered.

#### Accessories

